


NUMBER

TDS-3648


PRODUCT RANGE

ANACONDA COMPACT FITTINGS



PRODUCT DESCRIPTION

COMPACT 45° ELBOW FITTING, METRIC THREAD
STAINLESS STEEL AISI-316, UL/CSA APPROVED



THREAD TYPE	SEALTITE SIZE (INCH)	MIN. INTERNAL BORE (MM)	DIMENSIONS IN MM						STANDARD PACKAGE	ARTICLE NUMBER	WEIGHT (KG/100)
			A	B	C	D	E	F			
M16x1,5	5/16"	8,3	19	10	26	27	22	-	10	712.215.9*	6,70
M20x1,5	5/16"	8,3	20	10	26	28	24	-	10	712.214.9*	7,60
M16x1,5	3/8"	11,0	19	10	26	27	22	-	10	712.216.9	6,30
M20x1,5	3/8"	11,0	20	10	26	28	24	-	10	712.217.9	7,20
M20x1,5	1/2"	13,9	21	10	29	30	27	-	10	712.220.9	8,30
M25x1,5	3/4"	18,5	23	10	29	30	33	-	5	712.225.9	12,80
M32x1,5	1"	23,8	28	12	45	38	42	-	5	712.232.9	22,50
M40x1,5	1-1/4"	31,8	33	13	53	39	52	-	2	712.240.9	34,50
M50x1,5	1-1/2"	36,8	35	14	62	46	60	-	2	712.250.9	50,00
M63x1,5	2"	47,8	40	16	76	53	72	-	2	712.263.9	80,50

* Fittings for Sealtite conduit size 5/16" do not have UL / CSA approval.

APPLICATION AREA

Anaconda Compact stainless steel AISI-316 fittings can be used with all types of Anaconda Sealtite conduit with the exception of type CNP. The Anaconda compact range contains less material, are shorter in length and lighter in weight than the Anaconda standard range of fittings. They are ideal in standard applications and installations where space is limited. The fittings have a flanged ferrule which ensures a secure connection between fitting and conduit. and are UL & CSA approved.

MATERIAL & CONSTRUCTION:

Construction: 45° Elbow fitting consisting of 5 parts; back nut, clamping ring, ferrule, body and O-ring.

Material: Back nut and body are stainless steel AISI-316, ferrule is stainless steel AISI-304, clamping ring is Polyamide 6 and O-ring is NBR rubber.

Temperature: -45 °C till +105 °C continuous.

Protection class: IP 66, IP 67, NEMA 4X.

Colour: Metallic.

Special approvals: UL-514B and CSA C 22/2

(combined UL/CSA file# E 234207). Suitable for use in hazardous environments according to NEC:

- Article 501.10 (B) (2) Class I, Division 2
- Article 502.10 (A) (2) and (B) (2) Class II, Division 1 and 2.
- Article 503.10 (A) (3) and (B) Class III, Division 1 and 2.
- Fittings for Sealtite conduit size 5/16" do not have UL / CSA approval

Issued by:

Peter Rövekamp
Product Manager

Approved by:

Rob Guichelaar
Technical Manager

Date:

9 august 2024

Page:

1 of 1

